

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-1243:101 Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** Nibco Inc, 1516 Middlebury St., Elkhart IN 46515-1167  
Contact: \*Charles Stutsman (574) 295-3254 FAX (574) 523-3611

**DESIGN:** Model GD1765-4N, GD1765-8N, GD-4765-4N, and GD-4765-8N indicating butterfly valves. Sizes from 2 1/2", 3" outside diameter, 3", 4", 5", 6", 8" and 10" NPS. 10" NPS is for valves with modification only. Suffix -4N indicates valve without supervisory switch and suffix -8N indicates valve with supervisory switch. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Working pressure: 175 psi (GD-1765 Series)  
300 psi (GD-4765 Series)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL/FM label.

**APPROVAL:** Listed as indicating butterfly valves for use with fire sprinkler systems.

**NOTE:** Formerly 7768-1243:101

\*Rev. 0616-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**